



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

M101910005
Mike

JUL 06 2015

Chad Harris
Environmental Coordinator
Intrepid Potash – Moab, LLC
P.O. Box 1208
Moab, UT 84532

Dear Mr. Harris:

Subject: Mechanical Demonstration for Well 37H Review and Approval to Use
UIC Permit Number UTU-19-AP-1C3C2E8

The Division of Water Quality (DWQ) received a letter by email (July 2, 2015) explaining the workover on Well 37H to reestablish Mechanical Integrity. The workover consisted of three different mobilizations and the installation of a new swell packer assembly. After allowing the new swell packer sufficient time to swell a new Mechanical Integrity Test (MIT) was conducted on June 30, 2015. The results show that Mechanical Integrity has been reestablished.

Based on the review of the letter and the accompanying new well schematic and MIT results, DWQ hereby approves the use of well 37H.

Sincerely,

Woodrow Campbell, P.E.
Environmental Engineer
Ground Water Protection Section

WWC:DJH:ph

cc: David Ariotti, Southeastern Utah District name (via email)
Southeastern Utah District Health Department (via email)
Paul Baker, UDOGM Mineral Program Manager (via email)

DWQ-2015-007780